



RINA

17/01/2011

RSSE/ITMA/CAA/1349

T-ISS BV
Helmkamp 34
7091 HR Dinxperlo - Netherlands
Att: Mr.Verstegen

RINA NETHERLANDS B.V.
Blaak 504/508
3011 TA Rotterdam - Netherlands

2010CS014415

Type Approval of Spray Stop

Dear Mr. Verstegen,

with reference to Your request dated 04/10/2010, relevant to the matter in subject, please find here after attached, the Type Approval Certificate No. MAC441510CS and relevant invoice.

Best Regards

MACHINERY SECTION
ITALY PLAN APPROVAL CENTRE
MARINE DIVISION

+39 010 5385609
+ 5351484

Alessandro.Castello@rina.org
italy.planapproval@rina.org



TYPE APPROVAL CERTIFICATE
No. MAC441510CS

This is to certify that the product identified below is in compliance with the regulations herewith specified.

<i>Description</i>	Anti-splashing equipment
<i>Type</i>	T-ISS Spraystop Anti-Splash
<i>Applicant</i>	T-ISS BV HELMKAMP 34 7091 HR DINXPERLO NETHERLANDS
<i>Manufacturer</i>	T-ISS BV
<i>Place of manufacture</i>	HELMKAMP 34 7091 HR DINXPERLO NETHERLANDS
<i>Reference standards</i>	Chapter II-2 of Solas '74 as amended

Issued in **Genoa** on **January 17, 2011**. This Certificate is valid until **January 17, 2016**

RINA
Francesco Sciacca

This certificate consists of this page and 1 enclosure



TYPE APPROVAL CERTIFICATE

No. MAC441510CS

Enclosure - Page 1 of 1

T-ISS Spray Stop Anti-Splash

Technical characteristics

SPRAYSTOP anti-splash tape

Specification:

- Multilayer Alluminium/ Glasscloth/ PET liner with special adhesive.
- Surface printing/ Alluminium foil/ coated layer/ glassfiber layer/ silicon coated layer/ clear PET liner.

Rating:

According to Manufacturer's instructions.

Documents

- Pressure test, Ganewa by File number 2911/07/2005 dated 28-29-30/11/2005,
- Surface flammability test, FILK (Korea) File number 20050289.

Application limit

Anty-Spray Tape for screening pipe joints and fittings, in piping systems containing oil fuel or other flammable oils, in accordance with IMO SOLAS 74 as amended Regulation II-2/4.2.2.5.3.

The approval is restricted to piping systems which are readily accessible for maintenance and inspection purposes. The SPRAYSTOP anti-splash tape cannot be used for pipes insulation or as replacement for pipe gaskets and sealings.

The Manufacturer has to inform the users about proper methods of application and general maintenance of the SPRAYSTOP anti splash tape.

The installation on-board is to be satisfactorily witnessed by RINA Surveyor for each application on board ships.

Genoa 17/01/2011

